



We help ideas meet the real world

# Compliance Statement

No. 2015-159

## Screened Permanent Link, Class E<sub>A</sub>

### Company

Dätwyler Cabling Solutions AG  
Gotthardstrasse 31  
CH-6460 Altdorf  
Switzerland

### Permanent Link Identification (2 connector model)

#### Horizontal Cable:

DATWYLER Data Cable CU 6502 4P U/FTP Cat. 6<sub>A</sub> – Art. 191'453 – Lot: 830'097.01

#### Wall Outlet:

Module shielded KS-T Plus 1/8 Cat. 6<sub>A</sub> – Art. 418'061

### Generic cabling standards - Class E<sub>A</sub> Permanent Link requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-T210235-04, DANAK-19/15055

### EC Cabling product ID

5517

### CS valid until

1 May 2016

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 27 March 2015

Lars Lindskov Pedersen  
Test Manager

Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)

